



CONFERENCE REPORT

925 Bethel Street
5th Floor
Honolulu, HI 96813
808.523.5866
www.g70.design

TO:	ASEF II PROJECT FILE		
FROM:	Jeff Overton		
DATE:	November 16, 2017	LOCATION:	HCDA
PROJECT:	ASEF Kalaeloa Solar	PROJECT NO:	215073-01
SUBJECT:	HCDA Advisory Group Stakeholder Presentation	NO. OF PAGES:	2
THOSE PRESENT:	Tesha Malama, HCDA Pearlyn Fukuba, HCDA Ryan McCauley, Tritium3 Jeff Overton, G70	Attendees (see HCDA sign in sheet for listing)	

SUMMARY:

Presentation by ASEF II team: Jeff Overton, G70 and Ryan McCauley, Tritium3. Questions, comments and responses from the attendees followed.

1. Survey metes and bounds – ongoing for all Kalaeloa parcels
2. Electrical – establish company handling Kalaeloa like Hunt/Aqua for water and wastewater. Sandia is looking at microgrid recommendations.
3. Coordinate work March 2018? HECO review plans yet? A: Electrical contractor will be submitting plans for HECO review.
4. HECO live by December 2018? A: Depends upon the HECO plan review and approval process.
5. How tall poles where not underground? A: Poles are 36 ft on the DH side of Coral Sea Blvd. FAA reviewed and cleared the obstruction analysis.
6. Will construction affect airport operations? A: ASEF II will provide an update schedule / coordinate. U.S. Coast Guard is also pursuing electrical supply alternatives, and may ask HECO to connect to ASEF II 12KV extension. USCG must satisfy environmental review for project.
7. Overhead work vs. underground in electrical, coordination with district power system upgrade? Looking at extension of Keanolua Boulevard from Hoakalei. Many owners: Hunt, C&C Parks, DHHL, HI Air National Guard. Funding by DOT? All their players involved.
8. Can others connect to 12kv, such as USCG? A: HECO decides.
10. When will energy corridor come? A: 18 mo. to Ph1 Kapolei Pwy to ANG. Ph2 ANG to Midway.

Q: Duct lines going in. What about HECO organize each land owner must put in service request.

Q: Will cabling be installed? What will ASEF connect to? Only duct line installed then request service. Cabling from Kapolei Pwy via Langley. Cabling on Enterprise option for Coral Sea

EXHIBIT HH

UNLESS WRITTEN OBJECTION IS RECEIVED WITHIN SEVEN DAYS, WE ASSUME STATEMENTS CONTAINED WITHIN ARE ACCEPTED